

Some of the terms and abbreviations used in this report are:

- MCL:** Maximum Contaminant Level, the highest level of a contaminant that is allowed in drinking water.
MCLG: Maximum Contaminant Level Goal, the level of a contaminant in drinking water below which there is no known or expected risk to health.
MRDL: Maximum Residual Disinfectant Level, the highest level of disinfectant allowed in drinking water.
MRDLG: Maximum Residual Disinfectant Level Goal, the level of drinking water disinfectant below which there is no known or expected risk to health.
AL: Action Level, the concentration of a contaminant which, when exceeded, triggers treatment or other requirements or action which a system must follow.
TT: Treatment Technique, a required process intended to reduce the level of a contaminant in drinking water.
NTU: Nephelometric Turbidity Unit, a measure of the clarity (or cloudiness) of water.
ppm: parts per million, a measure for concentration equivalent to milligrams per liter.
ppb: parts per billion, a measure for concentration equivalent to micrograms per liter.
pCi/L: picocuries per liter, a measure for radiation.
P*: Potential violation, one that is likely to occur in the near future once the system has been sampled for four quarters.
n/a: either not available or not applicable.
ND: Not Detected, the result was not detected at or above the analytical method detection level.

Section I - Contaminants										
Inorganic Contaminants										
Date	Contaminant	MCL	MCLG	Unit	Result	Min	Max	Above AL Repeats	Violates	Likely Sources
2017	Barium	2	2	mg/l	<0.080				No	Discharge of drilling wastes; Discharge from metal refineries ;Erosion of natural deposits
2018	Nitrate	10	10	mg/l	0.05				No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
2017	Chromium	0.1	0.1	mg/l	<0.001				No	Discharge from steel and pulp mills; Erosion of natural deposits
2017	Thallium	0.002	0.0005	mg/l	<0.001				No	Discharge from electronics, glass, and leaching from ore processing sites; drug factories
2017	Fluoride	2	2	mg/l	<0.606				No	Erosion of natural deposits; Water Additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
2017	Copper (90th Percentile)	1.3AL	1.3	mg/l	0.624				No	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems
2017	Lead (90th Percentile)	0.015AL	0	mg/l	0.0057				No	Corrosion of household plumbing systems; Erosion of natural deposits
By-products & Precursors Disinfection										
Date	Contaminant	MCL	MCLG	Unit	Result	Min	Max	Above AL Repeats	Violates	Likely Sources
2018	Total Haloacetic Acids(haa5)	60		ppb	8				No	By product of drinking water chlorination
2018	Total Trihalomethanes (tthm)	80		ppb	16.8				No	By product of drinking water chlorination